


NOTE:
 SERVICE TAP TO BE MADE SLIGHTLY ABOVE SPRING LINE
 SO THAT COPPER LOOP SHALL NOT EXTEND ABOVE MAIN.
 MAINTAIN 7'-6" MINIMUM COVER FOR ALL SERVICE LINES.
 SADDLES SHALL BE USED FOR ALL CONNECTIONS TO
 6" OR SMALLER DIAMETER WATERMAINS.

NOTE: SEE STANDARD PLATE LV-ST-11
 FOR MnOPS REQUIREMENTS
 RELATED TO FUTURE LOCATING.

	WATERMAIN INSTALLATION OF IRRIGATION SYSTEM	PLATE NO. <u>LV-WM-8</u>
		DATE <u>02/2024</u>