



NOTE: ALL DRAINTILE MUST HAVE TRACER WIRE INSTALLED WITHIN THE TRENCH WHEN INSTALLED ALONG RURAL ROAD SECTIONS AND NOT BETWEEN STRUCTURES. TRACER WIRE WILL BE 8 GAUGE AND SHALL BE TAPED TO THE TOP OF PIPE AND WILL BE BROUGHT TO THE SURFACE AT EACH STRUCTURE OR CLEAN OUT. FOLLOW U.S.E. GUIDELINES FOR UNDERGROUND BURY. FOLLOWING COMPLETION CONTRACTOR WILL BE REQUIRED TO PERFORM A LOW VOLTAGE CONDUCTIVITY TEST.



STORM SEWER
STREET CROSSING
UNDERDRAIN DETAIL

PLATE NO. LV-STM-9A

DATE 02/2024